

Column1	Column2	PFAS Results	Column3	Column4	Column5	Column6
Garland Well	Date Sampled	PFOS--15 PPT	PFOA--12 PF	PFHxS--18 p	PFNA--11pp	Analytical Method
	Apr 2016	6 ppt	6 ppt	ND	ND	EPA 537
	Jan 2017	7.8 ppt6.9(DUP)	7.8 ppt7.1(D	NDND	ND	
	Jul 2017	11 ppt	10 ppt	5 ppt	ND	PFC Isotope
	Aug 2017	6 ppt	5 ppt	3 ppt	ND	
	Sept 2017	6 ppt	7 ppt	3 ppt	ND	
	Oct 2017	4 ppt	5 ppt	ND	ND	
	Nov 2017	5 ppt	4 ppt	ND	ND	
	Dec 2017	4 ppt	5 ppt	ND	ND	
	Jan 2018	6 ppt	5 ppt	ND	ND	
	Feb 2018	ND	4 ppt	ND	ND	
	Mar 2018	6 ppt	5 ppt	ND	ND	
	Apr 2018	ND	6 ppt	ND	ND	
	May 2018	ND	7 ppt	ND	ND	
	June 2018	5 ppt	7 ppt	ND	ND	
	July 2018	7 ppt	7 ppt	ND	ND	
	Aug 2018	6 ppt	6 ppt	ND	ND	
	Sept 2018	4 ppt	4 ppt	ND	ND	
	Oct 2018	7 ppt	6 ppt	ND	ND	
	Nov 2018	6 ppt	6 ppt	ND	ND	EPA 537
	Dec 2018	4 ppt	6 ppt	ND	ND	PFC Isotope
	Jan 2019	5 ppt	7 ppt	ND	ND	EPA 537
	Feb 2019	7 ppt	8 ppt	ND	ND	PFC Isotope
	Mar 2019	5 ppt	6 ppt	ND	ND	
	Apr 2019	ND	5 ppt	ND	ND	
	May 2019	6 ppt	6 ppt	ND	ND	
	June 2019	ND	6 ppt	ND	ND	
	July 2019	6 ppt	5 ppt	ND	ND	
	Aug 2019	6 ppt	6 ppt	ND	ND	
	Sept 2019	5 ppt	5 ppt	ND	ND	EPA 537
	Oct 2019	5 ppt	5 ppt	ND	ND	
	Nov 2019	5 ppt	5 ppt	ND	ND	
	Dec 2019	6.50 ppt	7.33 ppt	ND	ND	NH-537-Isotope
	Jan 2020	4.55 ppt	7.62 ppt	ND	ND	
	Feb 2020	6.04 ppt	7.14 ppt	ND	ND	
	Mar 2020	7.32 ppt	6.92 ppt	ND	ND	
	Apr 2020	5.64 ppt	8.03 ppt	ND	ND	
	May 2020	4.74 ppt	7.47 ppt	ND	ND	
	June 2020	6.75 ppt	6.82 ppt	ND	ND	EPA 533
	July 2020	6.29 ppt	6.44 ppt	ND	ND	
	Aug 2020	7.38 ppt	7.34 ppt	ND	ND	
	Sept 2020	5.22 ppt	6.51 ppt	2.12 ppt	ND	
	Oct 2020	6.80 ppt	6.91 ppt	ND	ND	
	Nov 2020	ND	ND	ND	ND	
	Dec 2020	7.69 ppt	6.20 ppt	ND	ND	

Jan 2021	6.04 ppt	6.76 ppt	ND	ND
Apr 2021	5.76 ppt	6.81 ppt	ND	ND
July 2021	5.72 ppt	6.52 ppt	ND	ND
Oct 2021	7.97ppt	7.72ppt	ND	ND
Feb 2022	6.85 ppt	8.64 ppt	ND	ND
Apr 2022	6.21 ppt	8.49 ppt	ND	ND
Aug 2022	8.47 ppt	8.97 ppt	2.09 ppt	ND
Nov 2022	7.93 ppt	5.87 ppt	ND	ND
3/29/2023	5.09	8.03	ND	ND
6/22/2023	6.36	6.72	ND	ND
7/17/2023	5.13	6.21	ND	ND
12/7/2023	4.84	5.8	1.09	ND

Garland Well	Date Sampled	PFOS--15 PPT	PFOA--12 PF	PFHxS--18 p	PFNA--11pp	Analytical Method
--------------	--------------	--------------	-------------	-------------	------------	-------------------

NHDES Regulatory Standards for 4 PFAS Maximum Contaminant Levels (MCLs) effective 09/30/19

PFOS--15 PP PFOA--12 PPT PFHxS--18 PPT PFNA--11 PPT

EPA Lifetime Health Advisory, dated 06/15/22

PFOS--0.02 P PFOA--0.004 ppt

Acroym Key--

PPT=parts per trillion (same as P) ND= Non Detect

Column1	Column2	PFAS Results	Column3	Column4	Column5	Column6
Baily Brook Well	Date Sampled	PFOS--15 PPT	PFOA--12 PP	PFHxS 18 PP	PFNA 11 PPT	Analytical Method
	Apr 2016	ND	ND	ND	ND	EPA 537
	Jan 2017	ND	2.5 ppt	ND	ND	
	Jul 2017	ND	ND	ND	ND	PFC Isotope
	Aug 2017	ND	ND	ND	ND	
	Sept 2017	ND	ND	ND	ND	
	Oct 2017	ND	ND	ND	ND	
	Nov 2017	ND	ND	ND	ND	
	Dec 2017	ND	ND	ND	ND	
	Jan 2018	ND	ND	ND	ND	
	Feb 2018	ND	ND	ND	ND	
	Mar 2018	ND	ND	ND	ND	
	Apr 2018	ND	ND	ND	ND	
	May 2018	ND	ND	ND	ND	
	June 2018	ND	ND	ND	ND	
	July 2018	ND	ND	ND	ND	
	Aug 2018	ND	ND	ND	ND	
	Sept 2018	ND	ND	ND	ND	
	Oct 2018	ND	ND	ND	ND	
	Nov 2018	ND	ND	ND	ND	EPA 537
	Dec 2018	ND	ND	ND	ND	PFC Isotope
	Jan 2019	ND	ND	ND	ND	EPA 537
	Feb 2019	ND	ND	ND	ND	PFC Isotope
	Mar 2019	ND	ND	ND	ND	
	Apr 2019	ND	ND	ND	ND	
	May 2019	ND	ND	ND	ND	
	June 2019	ND	ND	ND	ND	
	July 2019	ND	ND	ND	ND	
	Aug 2019	ND	ND	ND	ND	
	Sept 2019	ND	ND	ND	ND	EPA 537
	Oct 2019	ND	ND	ND	ND	
	Nov 2019	ND	ND	ND	ND	
	Dec 2019	ND	2.43 ppt	ND	ND	NH-537-Isotope
	Jan 2020	ND	2.42 ppt	ND	ND	
	Feb 2020	ND	2.29 ppt	ND	ND	
	Mar 2020	ND	2.34 ppt	ND	ND	
	Apr 2020	ND	2.45 ppt	ND	ND	
	May 2020	ND	ND	ND	ND	
	June 2020	ND	ND	ND	ND	
	July 2020	ND	ND	ND	ND	
	Aug 2020	ND	2.31 ppt	ND	ND	
	Sept 2020	ND	2.12 ppt	ND	ND	
	Oct 2020	ND	2.16 ppt	ND	ND	
	Nov 2020	ND	3.21 ppt	ND	ND	
	Dec 2020	ND	2.85 ppt	ND	ND	
	Jan 2021	ND	2.81 ppt	ND	ND	
	Apr 2021	ND	2.46 ppt	ND	ND	
	July 2021	ND	2.31 ppt	ND	ND	
	Oct 2021	ND	2.32 ppt	ND	ND	
	Feb 2022	ND	2.07 ppt	ND	ND	
	Apr 2022	ND	2.23 ppt	ND	ND	
	Aug 2022	ND	3.02 ppt	ND	ND	
	Nov 2022	ND	2.23 ppt	ND	ND	
	3/29/2023	ND	ND	ND	ND	
	6/22/2023	ND	ND	ND	ND	
	7/17/2023	ND	ND	ND	ND	
	12/7/2023	0.665	1.86	0.575	ND	

NHDES Regulatory Standards for 4 PFAS Maximum Contaminant Levels (MCLs) effective 09/30/19

PFOS--15 PPT PFOA--12 PPT PFHxS--18 PPT PFNA--11 PPT

EPA Lifetime Health Advisory, dated 06/15/22

PFOS--0.02 PPT PFOA--0.004 ppt

Acroym Key--

PPT=parts per trillion (same as ng/L) ND= Non Detect

Column1	Column2	PFAS Results	Column3	Column4	Column5	Column6
Cedar Run Well	Date Sampled	PFOS--15 PPT	PFOA--12 PF PFHxS--18 P	PFNA--11 PF		Analytical Method
	Apr 2016	ND	2 ppt	ND	ND	EPA 537
	Jan 2017	ND	3 ppt	ND	ND	
	Jul 2017	ND	ND	3 ppt	ND	PFC Isotope
	Aug 2017	ND	2 ppt	ND	ND	
	Sept 2017	ND	ND	ND	ND	
	Oct 2017	ND	ND	ND	ND	
	Nov 2017	ND	ND	ND	ND	
	Dec 2017	ND	2 ppt	ND	ND	
	Jan 2018	ND	3 ppt	ND	ND	
	Feb 2018	ND	ND	ND	ND	
	Mar 2018	ND	ND	ND	ND	
	Apr 2018	ND	ND	ND	ND	
	May 2018	ND	ND	ND	ND	
	June 2018	ND	ND	ND	ND	
	July 2018	ND	2 ppt	ND	ND	
	Aug 2018	ND	2 ppt	ND	ND	
	Sept 2018	ND	2 ppt	ND	ND	
	Oct 2018	ND	3 ppt	ND	ND	
	Nov 2018	ND	4 ppt	ND	ND	EPA 537
	Dec 2018	ND	3 ppt	ND	ND	PFC Isotope
	Jan 2019	ND	3 ppt	ND	ND	EPA 537
	Feb 2019	ND	ND	ND	ND	PFC Isotope
	Mar 2019	ND	4 ppt	ND	ND	
	Apr 2019	ND	2 ppt	ND	ND	
	May 2019	ND	2 ppt	ND	ND	
	June 2019	ND	3 ppt	ND	ND	
	July 2019	ND	4 ppt	ND	ND	
	Aug 2019	ND	4 ppt	ND	ND	
	Sept 2019	ND	4 ppt	ND	ND	EPA 537
	Oct 2019	ND	4 ppt	ND	ND	
	Nov 2019	ND	3 ppt	ND	ND	
	Dec 2019	ND	5.11 ppt	ND	ND	NH-537-Isotope
	Jan 2020	ND	5.67 ppt	ND	ND	
	Feb 2020	ND	4.85 ppt	ND	ND	
	Mar 2020	ND	4.72 ppt	ND	ND	
	Apr 2020	ND	5.23 ppt	ND	ND	
	May 2020	ND	4.36 ppt	ND	ND	
	June 2020	ND	4.39 ppt	ND	ND	EPA 533
	July 2020	2.06 ppt	4.28 ppt	2.06 ppt	ND	
	Aug 2020	ND	5.09 ppt	ND	ND	EPA 533
	Sept 2020	ND	4.32 ppt	ND	ND	
	Oct 2020	2.07 ppt	3.61 ppt	2.07 ppt	ND	
	Nov 2020	2.62 ppt	5.59 ppt	ND	ND	
	Dec 2020	2.77 ppt	5.13 ppt	2.04 ppt	ND	
	Jan 2021	2.62 ppt	5.17 ppt	3.04 ppt	ND	
	Apr 2021	ND	5.68 ppt	ND	ND	
	July 2021	ND	4.00 ppt	ND	ND	
	Oct 2021	2.12 ppt	5.47 ppt	2.26 ppt	ND	
	Feb 2022	ND	4.37 ppt	ND	ND	
	Apr 2022	ND	4.80 ppt	ND	ND	
	Aug 2022	2.43 ppt	5.59 ppt	ND	ND	
	Nov 2022	2.27 ppt	4.33 ppt	ND	ND	
	3/29/2023	ND	5.4	ND	ND	
	6/22/2023	ND	ND	ND	ND	
	7/17/2023	3.63	ND	ND	ND	
	12/7/2023	1.12	3.07	1.15	ND	

Cedar Run Well Date Sampled PFOS--15 PPT PFOA--12 PF PFHxS--18 P PFNA--11 PF Analytical Method

NHDES Regulatory Standards for 4 PFAS Maximum Contaminant Levels (MCLs) effective 09/30/19
PFOS--15 PPT PFOA--12 PPT PFHxS--18 PPT PFNA--11 PPT
EPA Lifetime Health Advisory, dated 06/15/22
PFOS--0.02 PPT PFOA--0.004 ppt

Acroym Key--

PPT=parts per trillion (same as ng/L) ND= Non Detect

Column1	Column2	Column3	Column4	Column5	Column6	Column7
Rye Water District--Per/Polyfluoroalkyl Substances (PFAS)		NHDES Maximum Contaminant Level (MCL) 15 PPT	12 PPT	18 PPT	11 PPT	
SystemSample(Taken@WashingtonRoadStorageTanks)	DateSampled	PFOS	PFOA	PFHxS	PFNA	AnalyticalMethod
	Aug 2017	7 ppt	4 ppt	ND	ND	PFC Isotope
	Sept 2017	5 ppt	3 ppt	ND	ND	
	Oct 2017	4 ppt	2 ppt	ND	3 ppt	
	Nov 2017	5 ppt	3 ppt	ND	ND	
	Dec 2017	ND	3 ppt	ND	ND	
	Jan 2018	ND	3 ppt	ND	ND	
	Feb 2018	ND	3 ppt	ND	ND	
	Mar 2018	ND	2 ppt	ND	ND	
	Apr 2018	5 ppt	3 ppt	ND	ND	
	May 2018	ND	4 ppt	ND	ND	
	June 2018	ND	5 ppt	ND	ND	
	July 2018	4 ppt	5 ppt	ND	ND	
	Aug 2018	ND	4 ppt	ND	ND	
	Sept 2018	ND	3 ppt	ND	ND	
	Oct 2018	ND	4 ppt	ND	ND	
	Nov 2018	4 ppt	4 ppt	ND	ND	EPA 537
	Dec 2018	ND	3 ppt	ND	ND	PFC Isotope
	Jan 2019	5 ppt	4 ppt	ND	ND	EPA 537
	Feb 2019	ND	5 ppt	ND	ND	PFC Isotope
	Mar 2019	ND	4 ppt	ND	ND	
	Apr 2019	ND	3 ppt	ND	ND	
	May 2019	ND	5 ppt	ND	ND	
	June 2019	ND	4 ppt	ND	ND	
	July 2019	ND	4 ppt	ND	ND	
	Aug 2019	4 ppt	4 ppt	ND	ND	
	Sept 2019	ND	4 ppt	ND	ND	EPA 537
	Oct 2019	2 ppt	4 ppt	ND	ND	
	Nov 2019	ND	ND	ND	ND	
	Dec 2019	3.56 ppt	4.80 ppt	ND	ND	NH-537-Isotope
	Jan 2020	3.66 ppt	5.45 ppt	ND	ND	
	Feb 2020	2.84 ppt	5.16 ppt	ND	ND	
	Mar 2020	4.52 ppt	5.21 ppt	ND	ND	
	Apr 2020	4.91 ppt	5.62 ppt	ND	ND	
	May 2020	2.90 ppt	5.40 ppt	ND	ND	
	June 2020	4.32 ppt	5.68 ppt	ND	ND	EPA 533
	July 2020	4.35 ppt	5.04 ppt	ND	ND	
	Aug 2020	4.42 ppt	5.11 ppt	ND	ND	
	Sept 2020	4.64 ppt	4.61 ppt	ND	ND	
	Oct 2020	5.31 ppt	5.31 ppt	ND	ND	
	Nov 2020	3.12 ppt	4.20 ppt	ND	ND	
	Nov 2020	4.69 ppt	5.32 ppt	ND	ND	
	Jan 2021	5.04 ppt	6.27 ppt	ND	ND	
	Apr 2021	4.35 ppt	5.71 ppt	ND	ND	
	July 2021	3.91 ppt	4.61 ppt	ND	ND	
	Oct 2021	4.63 ppt	4.70 ppt	ND	ND	
	Feb 2022	5.92 ppt	7.90 ppt	ND	ND	
	Apr 2022	4.02 ppt	5.74 ppt	ND	ND	
	Aug 2022	5.71 ppt	6.71 ppt	ND	ND	
	Nov 2022	5.23 ppt	5.24 ppt	ND	ND	
	3/29/2023	3.37	5.77	ND	ND	
	6/22/2023	4.12	5.42	ND	ND	
	7/17/2023	3.99	4.36	ND	ND	
	12/7/2023	3.53	4.53	ND	ND	

NHDES Regulatory Standards for 4 PFAS Maximum Contaminant Levels (MCLs) effective 09/30/19
PFOS--15 PPT PFOA--12 PPT PFHxS--18 PPT PFNA--11 PPT
EPA Lifetime Health Advisory, dated 06/15/22
PFOA--0.004
PFOS--0.02 PPT ppt
Acroym Key--
PPT=parts per trillion (same as ng/L) ND= Non Detect